

EC ATTESTATION OF CONFORMITY

EMC Directive: 2014 / 30 / EU LVD Directive: 2014 / 35 / EU

Including amendments "Council Directive on the approximation of the laws of the Member States relating to electromagnetic compatibility and low voltage"

Certificate Number: N 22 22785 0019 00 NY

Certificate Holder: TESCOM ELEKTRONİK SAN. VE TİC. A.Ş.

Dudullu OSB Mahallesi 2. Cad. Fabrikalar Sit. No: 7

Ümraniye / İSTANBUL / TÜRKİYE

Kind of Product: Static Transfer Switch

Trade Mark : Tescom

Series / Type Designation : STS 4000 Series

in compliance with the standards listed below proves the conformity of the designated products with the provisions of the EU Directive.

EN 62310-1 : 2005 EI EN 62310-2 : 2007

EN 62310-3 : 2008

EN ISO 7779 : 2018 ISO 9296 : 2017

100 3230 . 2017

Test Report Numbers: A 0019 22785 00 00 TK, L 0019 22785 00 00 ÖB C 0019 22785 00 00 ÖB, S 0019 22785 00 00 ÖB







Date: 30.09.2022 Dr. Nuh YALCIN **Due to:** 30.09.2024

CF

Consept is an independent inspection agency and testing laboratory in accordance with the EN ISO/IEC 17020 and EN ISO/IEC 17025.

"This certificate does not contain any statement pertaining to the EMC and LVD protection requirements governed by other laws to implement EC Directives other than the aforementioned Council Directive 2014/30/EU and 2014/35/EU." It confirms that the listed equipment complies with the principal protection requirements of the Directives and applies only to tested sample and its technical documentation submitted to the Consept for the testing and certification.

Certificate Number: N 22 22785 0019 00 NY

Page 1 of 2





ATTACHMENT

Certificate Number: N 22 22785 0019 00 NY

SANAYİ SİTESİ 10009 SOK. NO: 1 ULUKENT

MENEMEN / İZMİR / TÜRKİYE

Brand Name: Tescom®

Ratings and Principal Voltage: 180 -264 VAC 3 Phase/N/PE

characteristics
Frequency: 50/60Hz (48-52/56-64)
Current: 4 x 250 A - 4 Pole

Model (s) / Type Reference : STS 4050, STS 4100, STS 4150, STS 4200, STS 4250, STS 4300,

STS 4400, STS 4600 and STS 4800

Type key

Example: : STS YZ

STS: Series Name

Y: Number of phases

Z: Total power in kVA

Model Name		
Tested Model	Additional Model	Difference
STS 4250	STS 4050, STS 4100 STS 4150, STS 4200 STS 4300, STS 4400 STS 4600, STS 4800	Differencies only power elements. Chasing, cabling and all electronics circuits, part and pcb layouts are same in series.

Certificate Number: N 22 22785 0019 00 NY

Page 2 of 2

