CONSEPT®

EC ATTESTATION OF CONFORMITY

EMC Directive: 2014 / 30 / EU LVD Directive: 2014 / 35 / EU

Including amendments "Council Directive on the approximation of the laws of the Member States relating to electromagnetic compatibility and low voltage"

•	· · ·	•
Certificate Number :	N 22 22782 0019 00 NY	
Certificate Holder :	TESCOM ELEKTRONİK SAN. V Dudullu OSB Mahallesi 2. Cad. F Ümraniye / İSTANBUL / TÜRKİY	- abrikalar Sit. No: 7
Kind of Product :	Uninterruptible Power Supply	
Trade Mark :	v Tescom	
Series / Type Designation :	XA200 Series	\sim
in compliance with the standards I	isted below proves the conformity o	f the designated products with
the provisions of the EU Directive.		
EN IEC 62040-1 : 2019/A	11:2021 EN ISO 7779	: 2018
EN IEC 62040-2 : 2018	ISO 9296	: 2017
EN IEC 62040-3 : 2021		
Test Report Numbers : A 0	019 22782 00 00 TK, L 0019 22782	2 00 00 ÖB
C 0	019 22782 00 00 ÖB, S 0019 2278	2 00 00 ÖB
R ACCREDITED ACCREDITED PRODUCTION INSPECTED	CONSEPT & CROPE Kft. H – 1132 Budapest / Ascertidi u. 50/AB. 6/29. www.consept.com tr Cajisz: 01-09-341056	R CONSEPT CONSEPT CONSEPT
Date: 30.09.2022	Dr. Nuh YALCIN	Due to: 30.09.2024

Consept is an independent inspection agency and testing laboratory in accordance with the EN ISO/IEC 17020 and EN ISO/IEC 17025.

"This certificate does not contain any statement pertaining to the EMC and LVD protection requirements governed by other laws to implement EC Directives other than the aforementioned Council Directive 2014/30/EU and 2014/35/EU." It confirms that the listed equipment complies with the principal protection requirements of the Directives and applies only to tested sample and its technical documentation submitted to the Consept for the testing and certification.

Certificate Number: N 22 22782 0019 00 NY

Page 1 of 2

H – 1132 Budapest, Visegrádi u. 50/AB. 6./29. HUNGARY www.consept.hu

CONSEPT®

ATTACHMENT

Certificate Number	:	N 22 22782 0019 00 NY
Manufacturing Address	:	SANAYİ SİTESİ 10009 SOK. NO: 1 ULUKENT MENEMEN / İZMİR / TÜRKİYE
Brand Name	:	v Tescom
Ratings and Principal characteristics	:	Input: 380/400 VAC, 50/60 Hz, 3P+N Output: 220/230 VAC, 50/60 Hz, 1P+N Battery: 30x12V
Model (s) / Type Reference	:	XA210, XA215, XA220 and XA230
Type key		
Example:	:	XAYZ

Т

Example:		XAYZ
	XA :	: Series Name
	Υ:	Number of phases
	Z :	: Total power in kVA

Model Name		
Tested Model	Additional Model	Difference
XA230	XA210 XA215 XA220	Differencies only power elements. Chasing, cabling and all electronics circuits, part and pcb layouts are same in series.

Certificate Number: N 22 22782 0019 00 NY

Page 2 of 2

2

>

2