√ CERTIFICATE √ BIZONYÍTVÁNY √

CONSEPT®

EC ATTESTATION OF CONFORMITY

EMC Directive: 2014 / 30 / EU

LVD Directive: 2014 / 35 / EU

Including amendments “Council Directive on the approximation of the laws of the Member States relating to electromagnetic compatibility and low voltage”

Certificate Number : **N 25 23345 0019 00 NY**

Certificate Holder : TESCOM ELEKTRONİK SAN. VE TİC. A.Ş.
Dudullu OSB Mahallesi 2. Cad. Fabrikalar Sit. No: 7
Ümraniye / İSTANBUL / TÜRKİYE

Kind of Product : Uninterruptible Power Supply

Trade Mark : Tescom®

Series / Type Designation : **DS300H Series**

in compliance with the standards listed below proves the conformity of the designated products with the provisions of the EU Directive.

EN IEC 62040-1	: 2019/A11:2021	EN ISO 7779	: 2018
EN IEC 62040-2	: 2018	ISO 9296	: 2017
EN IEC 62040-3	: 2021		

Test Report Numbers : A 0019 23345 00 00 KK, L 0019 23345 00 00 SG
C 0019 23345 00 00 SG, S 0019 23345 00 00 SG

PRODUCTION INSPECTED

IAS ACCREDITED Inspection Agency IAS ACCREDITED Testing Laboratory

CONSEPT®
CONSEPT EUROPE Kft.
H – 1132 Budapest, Visegrádi u. 50/AB. 6./29.
www.consept.com.tr Cégjsz: 01-09-341056

Date: 28.03.2025 Dr. Nuh YALCIN **Due to:** 28.03.2026

CE

Consept is an independent inspection agency and testing laboratory in accordance with the EN ISO/IEC 17020 and EN ISO/IEC 17025.
“This certificate does not contain any statement pertaining to the EMC and LVD protection requirements governed by other laws to implement EC Directives other than the aforementioned Council Directive 2014/30/EU and 2014/35/EU.” It confirms that the listed equipment complies with the principal protection requirements of the Directives and applies only to tested sample and its technical documentation submitted to the Consept for the testing and certification.

CONSEPT®
H – 1132 Budapest, Visegrádi u. 50/AB. 6./29. HUNGARY
www.consept.hu

√ CERTIFICATE √ BIZONYÍTVÁNY √

ATTACHMENT

Certificate Number : **N 25 23345 0019 00 NY**

Manufacturing Address : SANAYİ SİTESİ 10009 SOK. NO: 1 ULUKENT MENEMEN / İZMİR / TÜRKİYE

Brand Name : Tescom®

Ratings and Principal characteristics : Input: 380/400VAC, 50/60Hz, 529/504 A, 3F+N
Output: 380/400VAC, 50/60Hz, 455/435 A, 3F+N
300kVA-300kW
Battery supply: 2 x 30 x12 V

Model (s) / Type Reference : **DS3200H, DS3250H and DS3300H**

Type key

Example: : **DSYZH**

DS H : Series Name

Y : Number of phases

Z : Total power in kVA

CONSEPT®

Model Name		Difference
Tested Model	**Additional Model**	
DS3300H	**DS3200H** **DS3250H**	Differencies only power elements. Chasing, cabling and all electronics circuits, part and pcb layouts are same in series.

CONSEPT®
H – 1132 Budapest, Visegrádi u. 50/AB. 6./29. HUNGARY
www.consept.hu